



3400 Summit Ridge Parkway
Duluth, Georgia 30096
Tel: 770-623-4332
Fax: 770-623-1847

Official Utilities Protection Center, Inc. Business Notification

UPC A/C Outage

Duluth, GA – August 22nd, 2007 – At or around 5:00pm today the Utilities Protection Center suffered a computer outage due to A/C unit failures. Both our primary and secondary A/C units for the UPC server room are currently down and are in the process of being repaired. At this time there is no estimated time of completion for the repairs. During this time UPC will be unavailable to receive or transmit locate requests.

If you need to report a damage or have an emergency during the outage, please contact the affected utility company directly, then report it to UPC after we are back online.

We apologize for this inconvenience.